

Wood Stove Inspection Checklist

Date: _____

Address: _____

Item	Yes	No
1. Is the stove listed by an independent testing lab?	<input type="checkbox"/>	<input type="checkbox"/>
2. Is the stove at least 36 inches from an unprotected wall or Combustible structures Installed per the manufacturer's requirements?	<input type="checkbox"/>	<input type="checkbox"/>
3. Is there a hearth or listed floor protector on the floor?	<input type="checkbox"/>	<input type="checkbox"/>
4. Does the floor protection extend at least 8 inches beyond the Non-opening sides of the stove?	<input type="checkbox"/>	<input type="checkbox"/>
5. Does the floor protection extend at least 18 inches on the Opening side(s) of the stove?	<input type="checkbox"/>	<input type="checkbox"/>
6. Is there not less than 36 inches of clearance from the stove to Any combustibles including structure, furnishings, and wood?	<input type="checkbox"/>	<input type="checkbox"/>
7. Is the stove stable and free of cracks or deficiencies?	<input type="checkbox"/>	<input type="checkbox"/>
8. Is the flue pipe free from cracks, rust, holes, and properly sized, And installed	<input type="checkbox"/>	<input type="checkbox"/>
9. Is there a damper on the flue pipe, or integrated in the stove?	<input type="checkbox"/>	<input type="checkbox"/>
10. If the chimney is masonry, is it lined? If it is metal is insulated, Multi-walled pipe?	<input type="checkbox"/>	<input type="checkbox"/>
11. Has the chimney been cleaned in the past 24 months?	<input type="checkbox"/>	<input type="checkbox"/>
12. Is there a metal can with a lid, and shovel for removing ash?	<input type="checkbox"/>	<input type="checkbox"/>

Inspector's Name _____

Signature _____